

GARDA UNO SPA – Unità Operativa Acque Potabili



SAN FELICE SUL BENACO



**ANALISI CHIMICO-FISICHE E BATTERIOLOGICHE
DELL' ACQUA DESTINATA AL CONSUMO UMANO**

(ANNO 2009)

FP VIA S.BONA

Parametri	U.M.	Limiti D.Lgs. 31/01	15/10	20/10	22/10	27/10	29/10	02/11	05/11	10/11	13/11	17/11	20/11	24/11
Cloro attivo libero	mg/l	0,2	0.22	0.20	0.14	0.25	0.25	0.26	0.22	0.22	0.28	0.25	0.20	0.24
Clorito	µg/l	700											487	
Bromato	µg/l	25 (10)											<5.0	
CBT a 22° C	UFC/1 ml	Senza variazioni	9	<1	3	29	10	<1	2	8	<1	<1	<1	<1
CBT a 36°C	UFC/1 ml	-	3	<1	<1	24	8	<1	<1	6	<1	<1	<1	<1
Coliformi a 37 °C	UFC/100 ml	0	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1
Enterococchi	UFC/100 ml	0	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1
E.Coli	UFC/100 ml	0	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1
Alghe	N°/100ml		<1	<1	<1	<1	<1	<1	<1	<1	<1		<1	<1
Tossine algali	Presenti/assenti		<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5		<0.5	<0.5
Clostridium Perfrigena			<1	<1	<1	<1	<1	<1	<1	<1	<1		<1	<1

FP VIA S.BONA

Parametri	U.M.	Limiti D.Lgs. 31/01	27/11	30/11	04/12	09/12	12/12	14/12	18/12	22/12	24/12			
Cloro attivo libero	mg/l	0,2	0.20	0.18	0.18	0.18	0.20	0.20	0.18	0.20	0.15			
CBT a 22° C	UFC/1 ml	Senza variazioni	<1	10	6	<1	<1	<1	<1	<1	4			
CBT a 36°C	UFC/1 ml	-	<1	<1	<1	<1	<1	<1	<1	<1	<1			
Coliformi a 37 °C	UFC/100 ml	0	<1	<1	<1	<1	<1	<1	<1	<1	<1			
Enterococchi	UFC/100 ml	0	<1	<1	<1	<1	<1	<1	<1	<1	<1			
E.Coli	UFC/100 ml	0	<1	<1	<1	<1	<1	<1	<1	<1	<1			
Alghe	N°/100ml		<1	<1	<1	<1	<1	<1	<1	<1	<1			
Tossine algali	Presenti/assenti		<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5			
Clostridium Perfrigena			<1	<1	<1	<1	<1	<1	<1	<1	<1			

FP VIA BENACO PORTESE

Parametri	U.M.	Limiti D.Lgs. 31/01	04/09	08/09	11/09	15/09	17/09	22/09	28/09	25/09	02/10	06/10	10/10	13/10
Cloro attivo libero	mg/l	0,2	0.24	0.20	0.20	0.18	0.20	0.25	0.20	0.25	0.20	0.20	0.20	0.20
CBT a 22° C	UFC/1 ml	Senza variazioni	6	<1	3	3	12	<1	<1	<1	<1	<1	<1	<1
CBT a 36°C	UFC/1 ml	-	<1	<1	<1	2	<1	<1	<1	<1	<1	<1	<1	<1
Coliformi a 37 °C	UFC/100 ml	0	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1
Enterococchi	UFC/100 ml	0	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1
E.Coli	UFC/100 ml	0	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1
Alghe	N°/100ml		<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1
Tossine algali	Presenti/assenti		<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5

FP VIA BENACO PORTESE

Parametri	U.M.	Limiti D.Lgs. 31/01	15/10	20/10	22/10	27/10	29/10	02/11	05/11	10/11	13/11	17/11	20/11	24/11
Cloro attivo libero	mg/l	0,2	0.24	0.20	0.16	0.16	0.25	0.24	0.20	0.25	0.25	0.22	0.20	0.20
Clorito	µg/l	700											544	
Bromato	µg/l	25 (10)											<5.0	
CBT a 22° C	UFC/1 ml	Senza variazioni	32	<1	<1	3	6	24	2	2	4	<1	5	<1
CBT a 36°C	UFC/1 ml	-	2	<1	<1	<1	5	12	<1	<1	<1	<1	<1	<1
Coliformi a 37 °C	UFC/100 ml	0	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1
Enterococchi	UFC/100 ml	0	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	
E.Coli	UFC/100 ml	0	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1
Alghe	N°/100ml		<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1
Tossine algali	Presenti/assenti		<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5

FP VIA BENACO PORTESE

Parametri	U.M.	Limiti D.Lgs. 31/01	27/11	30/11	04/12	09/12	12/12	14/12	18/12	22/12	24/12			
Cloro attivo libero	mg/l	0,2	0.18	0.14	0.20	0.16	0.20	0.18	0.16	0.18	0.20			
CBT a 22° C	UFC/1 ml	Senza variazioni	4	5	2	<1	<1	<1	<1	<1	<1			
CBT a 36°C	UFC/1 ml	-	2	<1	<1	<1	<1	<1	<1	<1	<1			
Coliformi a 37 °C	UFC/100 ml	0	<1	<1	<1	<1	<1	<1	<1	<1	<1			
Enterococchi	UFC/100 ml	0	<1	<1	<1	<1	<1	<1	<1	<1	<1			
E.Coli	UFC/100 ml	0	<1	<1	<1	<1	<1	<1	<1	<1	<1			
Alghe	N°/100ml		<1	<1	<1	<1	<1	<1	<1	<1	<1			
Tossine algali	Presenti/assenti		<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5			

